

Mills, Clarissa

From: Ranajit Sahu <sahuron@earthlink.net>
Sent: Tuesday, September 11, 2018 3:29 PM
To: Guerry, William M.
Cc: Mills, Clarissa
Subject: Re: FW: Requested Data and Follow-Up Discussion

Clarissa and Bill

I am available anytime on Friday for a call.

Bill, as to your question, the digesters are under slight positive pressure and therefore air/O₂ CANNOT be sucked in into the digesters and that is a good thing. I told Sarah that we do not want, under any circumstances, to every have the possibility of air/O₂ getting to the digesters - even when considering the repairs to the expansion joint. Thus, the repair has to be carefully thought through. Right now there are pin hole leaks in the expansion joint area where some methane may be coming out through a prior repair attempt.

We can discuss more when we talk.

Thanks

Ron

-----Original Message-----

From: "Guerry, William M."
Sent: Sep 11, 2018 11:15 AM
To: Ranajit Sahu
Cc: "Mills, Clarissa"
Subject: FW: Requested Data and Follow-Up Discussion

Ron—Can you please let me and Clarissa know your availability for the second technical call below? I also don't understand how the constant positive pressure in the AD buildings and roof would ever abruptly turn somehow into a negative-vacuum and suck in oxygen through any crack or opening? thanks

WILLIAM GUERRY

Partner

Kelley Drye & Warren LLP

Tel: (202) 342-8858

Cell: (301) 318-8719

wguerry@kelleydrye.com

From: Mills, Clarissa [mailto:mills.clarissa@epa.gov]
Sent: Tuesday, September 11, 2018 2:07 PM
To: Guerry, William M. <WGuerry@KelleyDrye.com>
Subject: RE: Requested Data and Follow-Up Discussion

Yes, does 10:00 a.m. work for you? Additionally, can we schedule a separate call with the technical folks to discuss the issue raised by Ron concerning the crack in the roof and oxygen getting into Digester 2?

Clarissa Howley Mills
Office of Regional Counsel
U.S. Environmental Protection Agency, Region 7
11201 Renner Boulevard
Lenexa, Kansas 66219
(913) 551-7743

CONFIDENTIALITY NOTE:

This email message is intended only for the personal use of the recipient(s) named above. This message is or may be an attorney client communication and as such privileged and confidential. If you are not the intended recipient(s) you may not review, copy or distribute this message. If you have received this message in error please notify the sender via return email and delete all copies of this message.

From: Guerry, William M. [<mailto:WGuerry@KelleyDrye.com>]
Sent: Tuesday, September 11, 2018 11:34 AM
To: Mills, Clarissa <mills.clarissa@epa.gov>
Cc: HertzWu, Sara <HertzWu.Sara@epa.gov>; Bill Tyndall <btyndall@netleasecapital.com>; Mike Major <mmajor@powerfulcompliance.com>
Subject: Re: Requested Data and Follow-Up Discussion

Clarissa.

Per our last call—Can we set up a call for tomorrow sometime before 11am your time to discuss the draft consent order? I plan to send you suggested edits and improvements before our call.

Thanks, Bill

Sent from my iPhone

On Sep 10, 2018, at 12:29 PM, Mills, Clarissa <mills.clarissa@epa.gov> wrote:

Bill –

I am currently on a conference call, so I missed your phone call, but wanted to confirm that my understanding is that of Sara's as well.

Clarissa Howley Mills
Office of Regional Counsel
U.S. Environmental Protection Agency, Region 7
11201 Renner Boulevard
Lenexa, Kansas 66219
(913) 551-7743

CONFIDENTIALITY NOTE:

This email message is intended only for the personal use of the recipient(s) named above. This message is or may be an attorney client communication and as such privileged and confidential. If you are not the intended recipient(s) you may not review, copy or distribute this message. If you have received this message in error please notify the sender via return email and delete all copies of this message.

From: HertzWu, Sara
Sent: Monday, September 10, 2018 11:26 AM
To: Guerry, William M. <WGuerry@KelleyDrye.com>; Mills, Clarissa <mills.clarissa@epa.gov>
Subject: RE: Requested Data and Follow-Up Discussion

Bill: I believe it is a stormwater inspection. I don't know that we know the list of documents. The people on the ground can ask the inspector for a list.

Regards,

Sara Hertz Wu
Assistant Regional Counsel
EPA Region VII
11201 Renner Boulevard
Lenexa, Kansas 66219
Phone: (913)551-7316
Email: hertzwu.sara@epa.gov
Fax: (913) 551-7925

From: Guerry, William M. [<mailto:WGuerry@KelleyDrye.com>]
Sent: Monday, September 10, 2018 11:20 AM
To: Mills, Clarissa <mills.clarissa@epa.gov>
Cc: HertzWu, Sara <HertzWu.Sara@epa.gov>
Subject: RE: Requested Data and Follow-Up Discussion

Clarissa

Thanks for the GMAP Report. I understand that an EPA Inspector is at BOE now requesting certain documents. Can you send me the list of documents that EPA is seeking today--so I can work through multiple contacts at BOE to try to expedite BOE providing the requested information. Thanks, Bill

WILLIAM GUERRY

Partner

Kelley Drye & Warren LLP
Tel: (202) 342-8858
Cell: (301) 318-8719
wguerry@kelleydrye.com

From: Mills, Clarissa [<mailto:mills.clarissa@epa.gov>]
Sent: Friday, September 07, 2018 4:35 PM
To: Guerry, William M. <WGuerry@KelleyDrye.com>
Cc: HertzWu, Sara <HertzWu.Sara@epa.gov>
Subject: BOE: Requested Data and Follow-Up Discussion

Bill –

As requested, please find attached the GMAP report.

Best,

CHM

Clarissa Howley Mills
Office of Regional Counsel
U.S. Environmental Protection Agency, Region 7
11201 Renner Boulevard
Lenexa, Kansas 66219
(913) 551-7743

CONFIDENTIALITY NOTE:

This email message is intended only for the personal use of the recipient(s) named above. This message is or may be an attorney client communication and as such privileged and confidential. If you are not the intended recipient(s) you may not review, copy or distribute this message. If you have received this message in error please notify the sender via return email and delete all copies of this message.

This message is subject to Kelley Drye & Warren LLP's email communication policy.

[KDW-Disclaimer](#)